



# LOWER TRINITY GROUNDWATER CONSERVATION DISTRICT

602 E. Church St. #150

Livingston, TX 77351

Office: (936) 327-9531

Fax: (936) 327-9532

Website: [WaterWells.Info](http://WaterWells.Info)

Email: [Groundwater@Livingston.net](mailto:Groundwater@Livingston.net)

## Water Well Spacing Guidelines *2020-2021*

### Residential Wells:

Pressure cemented wells:

Minimum distance from property line-5 feet

If not, pressure cemented -50ft from property line

Water-tight septic tank-50 feet

Soil absorption field-100 feet

Concentrated source of potential contamination, (Cattle yard, Poultry House)-150 feet

### Commercial Wells:

Pressure cemented wells:

Minimum distance from property line-150 feet

Water-tight septic tank-150 feet

Soil absorption field-150 feet

Concentrated source of potential contamination-150 feet

